



Request for Proposal("RFP")

Electric Pole Inspection & Treatment

RFP 25-010 Addendum No. 1 Questions from pre-bid meeting.

Question 1: If pole passes visual inspection and is older than 30 years old is treatment required?

A: Yes, treatment is required.

Questions 2: How to handle woodpecker holes?

A: Document and pictures. Will be addressed on a case-by-case basis.

Question 3. Who is responsible for notifying homeowners of work being done, when on homeowners' property?

A: Initial contract on contractor. If there is no answer, please leave the city supplied door hanger. If there is no contact made within 24 hours, report the issue to City staff.

Question4. Is Thor Poletest acceptable?

A: Yes, proposals utilizing Thor Poletest method will be accepted.